

Window Type	Series	Test		Report Number	Structural Class	Air Infiltration	Water * Test (PSF)	Min					Max				
		size	bs/vs					Width		Height		bs/vs	Width		Height		bs/vs
Half Vent	2110 2130 2130J 2170	6050	-	i4676.01-47-r0	LC-PG25	0.09	3.75	2	0	1	0	-	6	0	5	0	-
Double Vent		Nets size 120 x 72	36	i4675.01-47-r0	R-PG-15	0.08	2.92	4	0	1	0	12	10	0	6	0	36
Half Vent Below / Above		-	-	covered by i4678.01-901-47-cc,79	HS-R-20			2	0	2	0		6	0	6	0	
Double Vent Above		8060	48 / 24	i4678.01-901-47-cc	HS-R-20	0.06	3	4	0	2	0		8	0	6	0	48 / 24
Double Vent Below		8060	48 / 24	i4679.01-901-44-cc	HS-R-20	0.06	3	4	0	2	0		8	0	6	0	48 / 24
Single Hung	2210 2230 2230J	net 48 x 78	C	i4683.01-901-47-r0	H-LC-30	0.11	4.5	1	6	2	6	12	4	0	6	6	
Single Hung		Net 48 X 96	C	J3517.01-901-47-r0	H-LC-25	0.17	3.72	1	6	2	6		4	0	8	0	C
Single Hung		Net 48 X 96	39	J3481.01-901-47-r0	H-R-20	0.17	3.76	1	6	2	6		4	0	8	0	39
Triple Single Hung		net 108 x 78	C	i4684.01-901-47-r0	R-PG20	0.12	3	3	0	2	6	12	9	0	6	3	C
Picture Window	2310 2331	6060	-	i3982.01-901-47-r0	FW-LC-30	0.01	6	1	0	1	0	-	6	0	6	0	-
Picture Window	2340 2330 2330J	8060	-	i4687.01-901-47-r0	FW-LC-40	0.01	6	1	0	1	0	-	8	0	6	0	-
Picture Window	2350 2360 2360J 2375	Nest size 96 X 78	-	J3633.01-901-47 r0	FW-R-20	0.01	6.06	1	0	1	0		8	0	6	6	
Picture Window		6060	-	310-2359	FW-C-35	0.01	12	1	0	1	0	-	6	0	6	0	-
Awning	2410 2430	net 48 x 36	-	310-2350	AP-C-45	0.01	9	-		-		-	4	0	3	0	-
Full Awning stacked 2 vertically	2430J 2470	4060	-	310-2360	AW-C-40	0.03	9	-		-		-	4	0	6	0	-
Full Casement	2510 2530 2530J 2570	net 36 x 60	-	310-2351	C-C-40	0.05	7.5	-		-		-	3	0	5	0	-
Full Casement		net 36 x 72	-	310-2351	C-C-30	0.01	7.5	-		-		-	3	0	6	0	-
Single Casement		6060	36	310-2479	C-LC-30	0.01	9	-		-		-	6	0	6	0	36
Double Casement		net size 72 x 72	36	J3554.01-901-47-r0	C-R-20	0.2	4.59						6	0	6	0	36
Double Casement w/ center PW		net 143 x 60	36	310-2482	C-LC-25	0.08	7.5	-		-		-	11	11	5	0	36
Sliding Glass Door XO/OX	2610 2630 2610T 2630T	8080	48	i4689.01-901-47-R0	SD-LC-30	0.09	4.5	5	0	6	8	-	8	0	8	0	-
Sliding Glass Door OXO/XOO/OOX		12080	48	i4690.01-901-47 R0	SD-R-20	0.08	3	9	0	6	8	-	12	0	8	0	-
Sliding Glass Door OXXO		16080	48	i4691.01-901-47-R0	SD-R-20	0.13	3	10	0	6	8	-	16	0	8	0	-
Door Transom		9050	-	310-1476	TR-LC25	0.01	6.75	5	0	1	6	-	9	0	5	0	-

* The water test pressures are done in a controlled environment and performance in the field may vary. Therefore, AAMA requirements should be reduced to 2/3's of the test pressure for field testing.